

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

MS071 & AS071 - Fire resisting doorsets

Scope: Safety and performance requirements applicable to fire and/or smoke control products limited to;
Industrial, commercial and garage doors and gates according to the scope covered by EN 13241 or
Windows (including roof windows) and external pedestrian doorsets covered by EN 14351-1.

The product fulfils the essential characteristic of: See Annex 1

Intended use: Fire compartmentation and/or escape routes

Placed on the market under the name or trade mark of:
Door System A/S
Agerskovvej 16
8362 Hørning

and produced in the manufacturing plant:
CPA40009

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 16034:2014 : **Pedestrian doorsets, industrial, commercial, garage doors and openable windows - Product standard, performance characteristics - Fire resisting and/or smoke control characteristics**

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2021-11-30

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2020-06-07.)

This certificate was first issued 2020-05-29.



Lene Skovbjerg
Responsible for evaluation



Jesper Viggo Quaade
Responsible for certification decision

The certificate shall be reproduced in extensor
– extracts only with written permission from DBI Certification A/S.

Annex 1:

Product description: Fire resisting doorsets			
Essential Characteristics	Subclauses in this and other European Standard(s) related to essential characteristics	Performance	Remarks
Resistance to fire	4.1 (classification)	EI ₁ 30 EI ₂ 60 EW 60	
Smoke control	4.2 (classification)	NPD	
Ability to release	4.3 (description, test report)	Released	
Self-closing	4.4 (classification)	C	
Durability of ability to release	4.5.1 (description, test report)	NPD	
Durability of self-closing	4.5.2.1 (classification) 4.5.2.2 (description, test report)	NPD NPD	
	<ul style="list-style-type: none"> Against degradation (cycling testing) Against ageing (corrosion) 		

	Report no.	Date	Accredited Lab.
Classification report:	PCA10625A Rev. 2	2021-11-24	DBI, L0012
Exap report:	PHB10097A Rev. 02	2021-11-24	DBI, L0012
Test report:	PGA11908A Rev. 01	2021-11-11	DBI, L0012
	PGA11661A Rev. 0	2020-04-03	DBI, L0012
	PGA11661B Rev. 0	2020-04-03	DBI, L0012

The certificate shall be reproduced in extensor
 – extracts only with written permission from DBI Certification A/S.