



# Classification Report

## Steel door

---

**Name of sponsor:** Door System A/S  
**Product name:** MH075  
**File no.:** PCA10434A  
**Date:** 14-03-2017  
**Pages:** 8                      **Encl.:** 2  
**Ref:** JBK / TDJ

## 4 Classification

### Reference

---

This classification has been carried out in accordance with clause 7.5.5 of EN 13501-2:2016.

### Classification

---

The product is classified according to the following combinations of performance and classes as appropriate.

**Fire resistance classification:**                      **EI<sub>2</sub> 60-C\***

\* Depending on the use of door hardware, the door may be classified with or without the self-closing classification C.

The classification is valid for fire resistance from either side.