

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### MS071 & AS071 - Fire resisting doorsets

Scope: Safety and performance requirements applicable to fire and/or smoke control products limited to;  
Industrial, commercial and garage doors and gates according to the scope covered by EN 13241 or  
Windows (including roof windows) and external pedestrian doorsets covered by EN 14351-1.

The product fulfils the essential characteristic of: See Annex 1

Intended use: Fire and/or smoke compartmentation and/or escape routes

Placed on the market under the name or trade mark of:

**Door System A/S**  
**Agerskovvej 16**  
**8362 Hørning**  
**Denmark**

and produced in the manufacturing plant:

**CPA40009**

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

**EN 16034:2014** : **Pedestrian doorsets, industrial, commercial, garage doors and openable windows - Product standard, performance characteristics - Fire resisting and/or smoke control characteristics**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2020-05-29 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2025-02-12**

(This certificate supersedes the previous version of this certificate issued 2021-11-30)



Merete Poulsen  
Responsible for evaluation



Allan Christensen  
Responsible for certification decision

The certificate shall be reproduced in extensor  
– extracts only with written permission from DBI Certification A/S.

Annex 1:

Product description: Fire resisting doorsets			
Essential Characteristics	Subclauses in this and other European Standard(s) related to essential characteristics	Performance	Remarks
Resistance to fire	4.1 (classification)	EI <sub>1</sub> 30 EI <sub>2</sub> 60 EW 60	
Smoke control	4.2 (classification)	NPD	
Ability to release	4.3 (description, test report)	Released	
Self-closing	4.4 (classification)	C	
Durability of ability to release	4.5.1 (description, test report)	NPD	
Durability of self-closing	4.5.2.1 (classification) 4.5.2.2 (description, test report)	NPD NPD	
	<ul style="list-style-type: none"> <li>Against degradation (cycling testing)</li> <li>Against ageing (corrosion)</li> </ul>		

	Report no.	Date	Accredited Lab.
<b>Classification report:</b>	PCA10625A Rev. 3	2024-03-05	DBI, L0012
<b>Exap report:</b>	PHB10097A Rev. 3	2024-03-05	DBI, L0012
<b>Test report:</b>	PGA11908A Rev. 01	2021-11-11	DBI, L0012
	PGA11661A Rev. 0	2020-04-03	DBI, L0012
	PGA11661B Rev. 0	2020-04-03	DBI, L0012

**TECHNICAL BASIS**

The details of field of application including detailed build standard is described in the classification reports no. PCA10625A Rev. 3, 2024-03-05.

The certificate shall be reproduced in extensor  
 – extracts only with written permission from DBI Certification A/S.